

Yenda Sewer Treatment Plant Effluent Monitoring Data

EPA License number: 1402
License web link: <https://apps.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=1402&id=1402&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued>
Licensee: Griffith City Council
Licensee's address: 1 Neville Place, Griffith, NSW, 2680
Monitoring point: EPA 1, Whitton Stock Route, Yenda, NSW, 2681
Sampling frequency: Once every two months

Column1	Column2	Column3	Column4	Column5	Column6	Column7	Column8	Column9	Column10	Column11	Column12	Column13	Column14	Column15	Column16	Column17	Column18	Column19
	Sample date	Report Date	Published Date		Ammonia-N	BOD	Chlorophyll a	Electrical Conductivity	Faecal Coliforms	Nitrate	Nitrite	Oxidised Nitrogen	Oil & Grease	pH	Suspended Solids	TKN	Total Nitrogen	Total Phosphorus
				Units --->	mg/L	mg/L	µg/L	µS/cm	cfu/100mL	mg/L	mg/L	mg/L	mg/L		mg/L	mg/L	mg/L	mg/L
	02-Jul-24	17-Jul-24	17-Jul-24		17.8	18	7	1,275	12	0.0	0.0	0.1	2	7.7	4	19.4	19.5	7.1
	03-Sep-24	18-Sep-24	19-Sep-24		31.6	10	3.8	1,467	76	0.3	0.3	0.6	<1	7.8	5	37.8	38.4	7.0
	04-Nov-24	25-Nov-24	26-Nov-24		12.5	6	63	1,446	65	1.0	0.5	1.4	<1	8.2	12	14.8	16.2	5.6
			17-Mar-25															
	03-Mar-25	12-Mar-25	17-Mar-25		1.6	27	545	1,266	150	0.0	2.2	2.2	1	9.0	69	8.3	10.5	4.6
			22-May-25															

74.

July 2024:

All data within license limits.
75.

September 2024:

All data within license limits.
76.

November 2024:

All data within license limits.
77.

January 2025:

No data
78.

March 2025:

All data within license limits except suspended solids.
79.

May 2025:

No data