

Result Summary Report

Program:

Drinking Water Monitoring Program

Date Range: **01-07-2018 - 30-06-2019**

Water Utility:

Supply **Yenda GT02**

Barcode: All

Analysis Type: All

Characteristics: All

Sample Types: All

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	51	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	1.8804	1.8500	0.4209	1.15	3.1	51	0	2.7	1.24	100.00
	pH	6.5 - 8.5		7.9629	8.0000	0.1777	7.49	8.29	51	0	8.22	7.65	100.00
	Temperature	30.0000	C	20.2170	20.6000	5.4640	12	29.9	47	0	29.6	12.2	100.00
	Total Chlorine	5.0000	mg/L	2.0482	2.0100	0.4638	1.25	3.2	51	0	3.1	1.31	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	50	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1743	0.1600	0.0526	0.05	0.33	51	0	0.3	0.12	100.00