

Result Summary Report

Program:

Drinking Water Monitoring Program

Barcode:

All

Date

01-06-2019 - 30-06-2019

Analysis Type:

All

Water

Characteristics:

All

Supply

Yenda GT02

Sample Types:

All

System:

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	2.2125	2.0650	0.3263	2.02	2.7	4	0	2.7	2.02	100.00
	pH	6.5 - 8.5		8.1675	8.1750	0.0340	8.12	8.2	4	0	8.2	8.12	100.00
	Temperature	30.0000	C	14.3500	14.5500	1.8267	12	16.3	4	0	16.3	12	100.00
	Total Chlorine	5.0000	mg/L	2.3575	2.1450	0.4976	2.04	3.1	4	0	3.1	2.04	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1450	0.1400	0.0520	0.09	0.21	4	0	0.21	0.09	100.00