

Result Summary Report

Drinking Water Monitoring Program

Date Range: **01-06-2019 - 31-05-2020**

Analysis Type: All

Water Utility:

Characteristics: All

Supply System: **Yenda GT02**

Sample Types: All

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	52	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	1.7900	1.8050	0.6218	0.74	4.8	52	0	2.6	1.04	100.00
	pH	6.5 - 8.5		7.7052	7.6550	0.3091	7	8.25	52	0	8.2	7.14	100.00
	Temperature	30.0000	C	20.1442	21.0500	5.0782	11	28	52	0	27.6	12.7	100.00
	Total Chlorine	5.0000	mg/L	1.9437	1.9550	0.6594	0.89	5.2	52	1	2.8	1.15	98.08
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	52	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1754	0.1650	0.0700	0.07	0.4	52	0	0.33	0.08	100.00