

Result Summary Report

Drinking Water Monitoring Program

Date Range: **01-04-2019 - 30-04-2019**

Analysis Type: All

Water Utility:

Characteristics: All

Supply System: **Yenda GT02**

Sample Types: All

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	2.1260	1.8500	0.7817	1.33	3.1	5	0	3.1	1.33	100.00
	pH	6.5 - 8.5		7.9460	7.9400	0.2643	7.61	8.29	5	0	8.29	7.61	100.00
	Temperature	30.0000	C	22.1800	22.2000	1.0686	20.6	23.6	5	0	23.6	20.6	100.00
	Total Chlorine	5.0000	mg/L	2.3700	2.0700	0.7838	1.51	3.2	5	0	3.2	1.51	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1520	0.1500	0.0729	0.05	0.25	5	0	0.25	0.05	100.00